

From

Commissioner,
Municipal Corporation,
Gurgaon

To

M/s Raheja Developers Pvt. Ltd.,
215-216, Rectangle – 1, D-4,
Distt. Centre, Saket, New Delhi

No.. FS/MCG/2009/ 419


Dated: 01-09-09

Sub: - Approval of Fire Fighting Scheme from Fire Safety Point of view of the Residential Building measuring 10.668 Acre Vill. Dharampur, Sector-108, Gurgaon – Manesar Urban Complex of M/s Raheja Developers Ltd.

Reference your Letter dated 17-07-2009 and D.U.L.B letter No. FA/2009/ 32726 dated 28/8/09 on the subject cited above.

The case for the approval for the fire fighting scheme has been examined by the fire station officers, Gurgaon and Fire Officer (HQ) Chandigarh. The Fire fighting scheme is found as per the N.B.C. 1983 Part IV revised 2005. So the proposed fire fighting scheme is approved from fire safety point of view with the following conditions:-

- 1) The proposed fire fighting scheme is approved in the building plan submitted, subject to the approval of building plan as per rules applicable.
- 2) Overhead water tanks for fire fighting shall be constructed in such a way that domestic water tank shall be filled from overflow of fire Water tank.
- 3) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/tested and clearance should be obtained from this department.


For Commissioner, 1/9/09
Municipal Corporation,
Gurgaon *u r g*